

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority	Work Queue	Craft	Equipment
66089	Closed Work Orders Door handle on back door of room 7 is loose. I'm not sure if this is locksmith or maintenance. Thank you	10/23/2015 10/23/2015 Medium	Tammy Boyd	Classroom Key and Lock	Phoebe AHearst Room 7
82440	Closed Work Orders Screws came out of front door hinges. Door barely hanging on in room 7.	8/25/2016 9/14/2016 Medium	Robert Jacobs	Classroom Carpentry	Phoebe AHearst room 7
95880	Closed Work Orders Front door sticks. Needs to be sanded.	3/16/2017 3/20/2017 Medium	Robert Jacobs Shinn, Thomas	Classroom Carpentry	Phoebe AHearst room 7
95881	Closed Work Orders Slider sticks sometimes and teacher would like new curtains. Measure for new drapes. That may need relaxing in future. Repair track and master	3/16/2017 5/19/2017 Medium	Robert Jacobs stanley, Jeffrey	Classroom Shades/Blinds	Phoebe AHearst room 7
105351	Closed Work Orders Air conditioner leaking in room 7. Flush condensate line spom submit work order for roofers to check leaky roof	8/22/2017 9/22/2017 Medium	Robert Jacobs Magdaleno, Adriel	Classroom Heating/Ventilation /Air Conditioning	Phoebe AHearst room 7
131609	Closed Work Orders Bad ballast in Room 7. All four lights are out. Replaced ballast	9/26/2018 4/10/2019 Medium	Robert Jacobs Nagel, Christopher	Classroom Electrical	Phoebe AHearst room 7
150253	Closed Work Orders Air conditioning units leaking water in 7. 7 is leaking bad and seeping through the roof. 8-23-19 Came on site to check water leaks issue. Found that drain lines got plugged and condensate leaking on the roof. I will get pipe wrenches from plumbers and come back to disconnect lines and clear it. 8-30-19; Cleared condensate drain. Webb	8/22/2019 9/4/2019 Medium	Robert Jacobs Webb, Jack	Classroom Heating/Ventilation /Air Conditioning	Phoebe AHearst Room 7
157899	Closed Work Orders Teachers says her door sticks. Needs to be shaved.	12/16/2019 12/19/2019 Medium	Robert Jacobs Tirapelle, Thomas	Classroom Carpentry	Phoebe AHearst room 7

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority	Work Queue	Craft	Equipment
174204	Closed Work Orders Whiteboard needs replacing.	2/10/2021 4/25/2022 Medium	Robert Jacobs Ketchum, Roger	Classroom Carpentry	Phoebe AHearst room 7
180573	Closed Work Orders Water damage to ceiling tile in room 7. Fit report.	6/21/2021 6/25/2021 Medium	Robert Jacobs Boland, Brian	Classroom Carpentry	Phoebe AHearst room 7
183807	Void Need whiteboards replaced in room 7.	8/25/2021 Medium	Robert Jacobs	Classroom Carpentry	Phoebe AHearst Room 7
221035	Closed Work Orders We have a carpet in room 7 that the teacher would like to have removed. Thank you. Carpet needs cleaning	6/26/2023 4/8/2024 Medium	Anthony Renda Kaestner, Joshua	 Flooring	Phoebe AHearst Room 7
230346	Closed Work Orders Room 7 and 11 Heaters are not coming on. Fans seem to be blowing but furnace is not kicking in. Thank you. 11-27-23 Checked operation, no mechanical issues found at this time (AC unit for room #7). Control module need to be checked by contractor.	11/27/2023 12/5/2023 Medium	Anthony Renda Strilets, Sergey	 Heating/Ventilation /Air Conditioning	Phoebe AHearst Room 7 & 11
234360	Closed Work Orders We have one large branch down by room 7. Thank you Removed branch from tree	2/5/2024 2/9/2024 Medium	Anthony Renda Hall, Michael	 Laborer	Phoebe AHearst hallway by room 7
235821	Closed Work Orders Room 7 Has a bad ballast. Thank you. Replaced ballast	2/27/2024 3/22/2024 Medium	Anthony Renda Gomes, Aaron	 Electrical	Phoebe AHearst Room 7
235822	Closed Work Orders Room 7 is asking again that their carpet be removed. It is heavily stained and frayed at some parts. Teacher would prefer her room to be all tile. Thank you. Room was replaced	2/27/2024 9/16/2025 Medium	Anthony Renda Kaestner, Joshua	 Flooring	Phoebe AHearst Room 7

Work Order Search Results

Work OrderID	Status	Request Date	Requester	Area Type	Location
	Description	Completion Date	Assigned To	Building	Area Number
	Action Taken	Priority	Work Queue	Craft	Equipment
239357	Closed Work Orders	4/29/2024	Anthony Renda		Phoebe AHearst
	Room 7 drinking fountain in very low pressure. Water only dribbles out. Thank you.	7/3/2024			Room 7
	installed used drinking fountain.	Medium		Plumbing	
255412	Closed Work Orders	1/9/2025	Anthony Renda		Phoebe AHearst
	Room 7 water fountain has broken loose, needs to be resealed to the tile. Thank you.	1/22/2025	Watson, Wade		Room 7
	re mounted drinking fountain.	Medium		Plumbing	
258414	Closed Work Orders	2/20/2025	Anthony Renda		Phoebe AHearst
	Room 7 drinking fountain is loose again. Sealant has cracked and the fountain was leaking. I have turned off the water. Thank you.	2/25/2025	Watson, Wade		Room 7
	had to cut stem of bubbler head to add cupling to extend to make it possible. had to use large escution and washer to make tight then caulk and test	Medium		Plumbing	
265067	Closed Work Orders	6/12/2025	Anthony Renda		Phoebe AHearst
	Room 7 carpet was ripped up by the teacher without my knowledge. Will need assistance removing the adhesive from the tiles. Thank you.	9/3/2025	Kaestner, Joshua		Room 7
	Replaced flooring in classroom	Medium		Flooring	